

# Test report

**340891-1TRFEMC**

Date of issue: November 30, 2017

Applicant:

**MRI Audio**

Product:

**MRI Audio System**

Models:

**MRludioPREM-1000(tested) & MRludioPREM-1001**

Specification:

**IEC 60601-1-2: 2014**

Medical electrical equipment —


PART 1-2: General requirements for basic safety and essential performance —

Collateral standard: Electromagnetic compatibility — Requirements and tests

#### Lab and test locations

---

Company name	Nemko USA, Inc.
Address	2210 Faraday Ave, Suite 150
City	Carlsbad
State	California
Postal code	92008
Country	USA
Telephone	+1 760 444 3500
Website	www.nemko.com
Site number	FCC: US5058; IC: 2040B
Company name	Nemko USA, Inc.
Website	www.nemko.com

Tested by	Rodel Resolme, EMC Test Engineer
Reviewed by	Mark Phillips, Sr. EMC Test Engineer
Review date	November 30, 2017
Reviewer signature	

#### Limits of responsibility

---

Note that the results contained in this report relate only to the items tested and were obtained in the period between the date of initial receipt of samples and the date of issue of the report.

This test report has been completed in accordance with the requirements of ISO/IEC 17025. All results contain in this report are within Nemko USA ISO/IEC

#### Copyright notification

---

Nemko USA Inc. authorizes the applicant to reproduce this report provided it is reproduced in its entirety and for use by the company's employees only. Any use which a third party makes of this report, or any reliance on or decisions to be made based on it, are the responsibility of such third parties.

Nemko USA Inc. accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions based on this report.

© Nemko USA Inc.

## Table of Contents

<b>Table of Contents</b> .....	<b>3</b>
<b>Section 1 Report summary</b> .....	<b>4</b>
1.1 Test specifications .....	4
1.2 Statement of compliance.....	4
1.3 Exclusions .....	4
1.4 Test report revision history.....	4
<b>Section 2 Summary of test results</b> .....	<b>5</b>
2.1 Test results .....	5
<b>Section 3 Equipment under test (EUT) details</b> .....	<b>10</b>
3.1 Applicant.....	10
3.2 Manufacturer.....	10
3.3 Sample information .....	10
3.4 EUT information .....	10
3.5 EUT exercise and monitoring details .....	10
3.6 EUT setup details .....	11
<b>Section 4 Engineering considerations</b> .....	<b>13</b>
4.1 Modifications incorporated in the EUT.....	13
4.2 Technical judgment .....	13
4.3 Deviations from laboratory tests procedures .....	13
<b>Section 5 Test conditions</b> .....	<b>14</b>
5.1 Atmospheric conditions.....	14
5.2 Power supply range .....	14
<b>Section 6 Measurement uncertainty</b> .....	<b>15</b>
6.1 Uncertainty of measurement .....	15
<b>Section 7 Terms and definitions</b> .....	<b>16</b>
7.1 Performance criterion.....	16
<b>Section 8 Testing data</b> .....	<b>17</b>
8.1 Radiated RF emissions .....	17
8.2 Conducted RF emissions .....	22
8.3 Harmonic distortion.....	26
8.4 Voltage fluctuations/flicker emissions .....	32
8.5 Radiated RF EM field.....	36
8.6 Proximity fields from RF wireless communications equipment .....	39
8.7 Conducted disturbances induced by RF fields .....	42
8.8 Electrostatic discharge.....	45
8.9 Surge.....	51
8.10 Electrical fast transients/bursts .....	54
8.11 Voltage dips and interruptions .....	57
8.12 Power-frequency magnetic field.....	60
<b>Section 9 EUT photos</b> .....	<b>63</b>
9.1 External photos.....	63

## Section 1 Report summary

---

### 1.1 Test specifications

---

IEC 60601-1-2: 2014

Medical electrical equipment —  
 PART 1-2: General requirements for basic safety and essential performance —  
 Collateral standard: Electromagnetic compatibility — Requirements and tests

### 1.2 Statement of compliance

---

In the configuration tested, the EUT was found compliant.

Testing was completed against all relevant requirements of the test standard. Results obtained indicate that the product under test complies in full with the requirements tested. The test results relate only to the items tested.

See “Summary of test results” for full details.

### 1.3 Exclusions

---

None

### 1.4 Test report revision history

---

**Table 1.4-1: Test report revision history**

Revision #	Details of changes made to test report
TRF	Original report issued

## Section 2 Summary of test results

### 2.1 Test results

**Table 2.1-1: EM Environments**

EM Environments		
<input checked="" type="checkbox"/>	Professional healthcare facility environment	Physician offices, dental offices, clinics, limited care facilities, freestanding surgical centers, freestanding birthing centers, multiple treatment facilities, hospitals (emergency rooms, patient rooms, intensive care, surgery rooms except near HF SURGICAL EQUIPMENT, outside the RF shielded room of an ME SYSTEM for magnetic resonance imaging)
<input type="checkbox"/>	HOME HEALTHCARE ENVIRONMENT	Restaurants, cafes, shops, stores, markets, schools, churches, libraries, outdoors (streets, sidewalks, parks), domiciles (residences, homes, nursing homes), vehicles (cars, buses, trains, boats, planes, helicopters), train stations, bus stations, airports, hotels, hostels, pensions, museums, theatres
<input type="checkbox"/>	Special environment	Military areas (submarines, near radar installations, near weapons control systems), heavy industrial areas (power plants, steel and paper mills, foundries, automotive and appliance manufacturing, smelting and mining operations, oil and gas refineries), medical treatment areas with high-powered ME EQUIPMENT (HF SURGICAL EQUIPMENT, SHORT-WAVE THERAPY EQUIPMENT, inside the RF shielded room of an ME SYSTEM for magnetic resonance imaging)

Notes: Although healthcare professionals are present in the EMERGENCY MEDICAL SERVICES ENVIRONMENT, the ELECTROMAGNETIC ENVIRONMENT is similar to that of the HOME HEALTHCARE ENVIRONMENT. Therefore, for the purposes of this collateral standard, the EMISSIONS and IMMUNITY requirements of the HOME HEALTHCARE ENVIRONMENT apply to ME EQUIPMENT and ME SYSTEMS intended for use in the EMERGENCY MEDICAL SERVICES ENVIRONMENT. An example of such a location is an ambulance.

**Table 2.1-2: Emission results**

Phenomenon	Professional healthcare facility environment	HOME HEALTHCARE ENVIRONMENT	Verdict
Radiated RF EMISSIONS	CISPR 11	CISPR 11 <sup>b), c)</sup>	Pass
Conducted RF EMISSIONS	CISPR 11	CISPR 11 <sup>b), c)</sup>	Pass
Harmonic distortion	IEC 61000-3-2 <sup>a)</sup>	IEC 61000-3-2	Pass
Voltage fluctuations and flicker	IEC 61000-3-3 <sup>a)</sup>	IEC 61000-3-3	Pass

Notes: <sup>a)</sup> This test is not applicable in this environment unless the ME EQUIPMENT and ME SYSTEMS used there will be connected to the PUBLIC MAINS NETWORK and the power input is otherwise within the scope of the Basic EMC standard.

<sup>b)</sup> ME EQUIPMENT and ME SYSTEMS intended for use in aircraft shall meet the RF EMISSIONS requirements of ISO 7137. The conducted RF EMISSIONS test is applicable only to ME EQUIPMENT and ME SYSTEMS that are intended to be connected to aircraft power. ISO 7137 is identical to RTCA DO-160C:1989 and EUROCAE ED-14C:1989. The latest editions are RTCA DO-160G: 2010 and EUROCAE ED-14G: 2011. Therefore, use of Section 21 (and category M) of a more recent edition, e.g. [39] or [40], should be considered.

<sup>c)</sup> Standards applicable to other modes or EM ENVIRONMENTS of transportation for which use is intended shall apply. Examples of standards that might be applicable include CISPR 25 and ISO 7637-2.

<sup>1</sup> Group 1 Class A

## 2.1 Test results, continued

Table 2.1-3: Enclosure port results

Phenomenon	Basic EMC standard or test method	Immunity test levels		Verdict
		Professional healthcare facility environment	HOME HEALTHCARE ENVIRONMENT	
Electrostatic discharge	IEC 61000-4-2	± 8 kV contact ± 2 kV, ±4 kV, ±8 kV, ±15 kV air		Pass
Radiated RF EM fields <sup>a)</sup>	IEC 61000-4-3	3 V/m <sup>f)</sup> 80 MHz – 2.7 GHz <sup>b)</sup> 80 % AM at 1 kHz <sup>c)</sup>	10 V/m <sup>f)</sup> 80 MHz – 2.7 GHz <sup>b)</sup> 80 % AM at 1 kHz <sup>c)</sup>	Pass
Proximity fields from RF wireless communications equipment	IEC 61000-4-3	See Clause 8.10 of IEC 60601-1-2.		Pass
Rated power frequency magnetic fields <sup>d) e)</sup>	IEC 61000-4-8	30 A/m <sup>g)</sup> 50 Hz or 60 Hz		Pass

Notes:

- <sup>a)</sup> The interface between the PATIENT physiological signal simulation, if used, and the ME EQUIPMENT or ME SYSTEM shall be located within 0,1 m of the vertical plane of the uniform field area in one orientation of the ME EQUIPMENT or ME SYSTEM.
- <sup>b)</sup> ME EQUIPMENT and ME SYSTEMS that intentionally receive RF electromagnetic energy for the purpose of their operation shall be tested at the frequency of reception. Testing may be performed at other modulation frequencies identified by the RISK MANAGEMENT PROCESS. This test assesses the BASIC SAFETY and ESSENTIAL PERFORMANCE of an intentional receiver when an ambient signal is in the passband. It is understood that the receiver might not achieve normal reception during the test.
- <sup>c)</sup> Testing may be performed at other modulation frequencies identified by the RISK MANAGEMENT PROCESS.
- <sup>d)</sup> Applies only to ME EQUIPMENT and ME SYSTEMS with magnetically sensitive components or circuitry.
- <sup>e)</sup> During the test, the ME EQUIPMENT or ME SYSTEM may be powered at any NOMINAL input voltage, but with the same frequency as the test signal (see Table 1).
- <sup>f)</sup> Before modulation is applied.
- <sup>g)</sup> This test level assumes a minimum distance between the ME EQUIPMENT or ME SYSTEM and sources of power frequency magnetic field of at least 15 cm. If the RISK ANALYSIS shows that the ME EQUIPMENT or ME SYSTEM will be used closer than 15 cm to sources of power frequency magnetic field, the IMMUNITY TEST LEVEL shall be adjusted as appropriate for the minimum expected distance.

## 2.1 Test results, continued

Table 2.1-4: Input a.c. power port results

Phenomenon	Basic EMC standard or test method	Immunity test levels		Verdict
		Professional healthcare facility environment	HOME HEALTHCARE ENVIRONMENT	
Electrical fast transients/bursts <sup>a), l), o)</sup>	IEC 61000-4-4	± 2 kV 100 kHz repetition frequency		Pass
Surges <sup>a), b), j), o)</sup>	IEC 61000-4-5	± 0.5 kV, ±1 kV		Pass
Line-to-line				
Surges <sup>a), b), j), k), o)</sup>	IEC 61000-4-5	± 0.5 kV, ±1 kV, ±2 kV		Pass
Line-to-ground				
Conducted disturbances induced by RF fields <sup>c), d), o)</sup>	IEC 61000-4-6	3 V <sup>m)</sup> 0,15 – 80 MHz	3 V <sup>m)</sup> 0,15 – 80 MHz	Pass
		6 V <sup>m)</sup> in ISM bands between 0.15 MHz and 80 MHz <sup>n)</sup>	6 V <sup>m)</sup> in ISM and amateur radio bands between 0.15 MHz and 80 MHz <sup>n)</sup>	
Voltage dips <sup>f), p), r)</sup>	IEC 61000-4-11	80 % AM at 1 kHz 0 % U <sub>r</sub> ; 0,5 cycle <sup>g)</sup> , @ 0°, 45°, 90°, 135°, 180°, 225°, 270° and 315° <sup>q)</sup>	80 % AM at 1 kHz	Pass
		0 % U <sub>r</sub> ; 1 cycle and 70% U <sub>r</sub> ; 25/30 cycles <sup>h)</sup> , @ 0°		
Voltage interruptions <sup>f), i), o), r)</sup>	IEC 61000-4-11	0 % U <sub>r</sub> ; 250/300 cycle <sup>h)</sup>		Pass

## Notes:

- <sup>a)</sup> The test may be performed at any one power input voltage within the ME EQUIPMENT or ME SYSTEM RATED voltage range. If the ME EQUIPMENT or ME SYSTEM is tested at one power input voltage, it is not necessary to re-test at additional voltages.
- <sup>b)</sup> All ME EQUIPMENT and ME SYSTEM cables are attached during the test.
- <sup>c)</sup> Calibration for current injection clamps shall be performed in a 150 Ω system.
- <sup>d)</sup> If the frequency stepping skips over an ISM or amateur band, as applicable, an additional test frequency shall be used in the ISM or amateur radio band. This applies to each ISM and amateur radio band within the specified frequency range.
- <sup>e)</sup> Testing may be performed at other modulation frequencies identified by the RISK MANAGEMENT PROCESS.
- <sup>f)</sup> ME EQUIPMENT and ME SYSTEMS with a d.c. power input intended for use with a.c.-to-d.c. converters shall be tested using a converter that meets the specifications of the MANUFACTURER of the ME EQUIPMENT or ME SYSTEM. The IMMUNITY TEST LEVELS are applied to the a.c. power input of the converter.
- <sup>g)</sup> Applicable only to ME EQUIPMENT and ME SYSTEMS connected to single-phase a.c. mains.
- <sup>h)</sup> E.g. 10/12 means 10 periods at 50 Hz or 12 periods at 60 Hz.
- <sup>i)</sup> ME EQUIPMENT and ME SYSTEMS with RATED input current greater than 16 A / phase shall be interrupted once for 250/300 cycles at any angle and at all phases at the same time (if applicable). ME EQUIPMENT and ME SYSTEMS with battery backup shall resume line power operation after the test. For ME EQUIPMENT and ME SYSTEMS with RATED input current not exceeding 16 A, all phases shall be interrupted simultaneously.
- <sup>j)</sup> ME EQUIPMENT and ME SYSTEMS that do not have a surge protection device in the primary power circuit may be tested only at ± 2 kV line(s) to earth and ± 1 kV line(s) to line(s).
- <sup>k)</sup> Not applicable to CLASS II ME EQUIPMENT and ME SYSTEMS.
- <sup>l)</sup> Direct coupling shall be used.
- <sup>m)</sup> r.m.s., before modulation is applied.
- <sup>n)</sup> The ISM (industrial, scientific and medical) bands between 0,15 MHz and 80 MHz are 6,765 MHz to 6,795 MHz; 13,553 MHz to 13,567 MHz; 26,957 MHz to 27,283 MHz; and 40,66 MHz to 40,70 MHz. The amateur radio bands between 0,15 MHz and 80 MHz are 1,8 MHz to 2,0 MHz, 3,5 MHz to 4,0 MHz, 5,3 MHz to 5,4 MHz, 7 MHz to 7,3 MHz, 10,1 MHz to 10,15 MHz, 14 MHz to 14,2 MHz, 18,07 MHz to 18,17 MHz, 21,0 MHz to 21,4 MHz, 24,89 MHz to 24,99 MHz, 28,0 MHz to 29,7 MHz and 50,0 MHz to 54,0 MHz.
- <sup>o)</sup> Applicable to ME EQUIPMENT and ME SYSTEMS with RATED input current less than or equal to 16 A / phase and ME EQUIPMENT and ME SYSTEMS with RATED input current greater than 16 A / phase.
- <sup>p)</sup> Applicable to ME EQUIPMENT and ME SYSTEMS with RATED input current less than or equal to 16 A / phase.
- <sup>q)</sup> At some phase angles, applying this test to ME EQUIPMENT with transformer mains power input might cause an overcurrent protection device to open. This can occur due to magnetic flux saturation of the transformer core after the voltage dip. If this occurs, the ME EQUIPMENT or ME SYSTEM shall provide BASIC SAFETY during and after the test.
- <sup>r)</sup> For ME EQUIPMENT and ME SYSTEMS that have multiple voltage settings or auto ranging voltage capability, the test shall be performed at the minimum and maximum RATED input voltage. ME EQUIPMENT and ME SYSTEMS with a RATED input voltage range of less than 25 % of the highest RATED input voltage shall be tested at one RATED input voltage within the range. See Table 1 Note c) for examples calculations.

## 2.1 Test results, continued

Table 2.1-5: PATIENT coupling PORT results

Phenomenon	Basic EMC standard or test method	Immunity test levels		Verdict
		Professional healthcare facility environment	HOME HEALTHCARE ENVIRONMENT	
ELECTROSTATIC DISCHARGE <sup>d)</sup>	IEC 61000-4-2	± 8 kV contact ± 2 kV, ±4 kV, ±8 kV, ±15 kV air		Not applicable
Conducted disturbances induced by RF fields a)	IEC 61000-4-6	3 V <sup>b)</sup>	3 V <sup>b)</sup>	
		0,15 – 80 MHz	0,15 – 80 MHz	
		6 V <sup>b)</sup> in ISM bands between 0.15 MHz and 80 MHz	6 V <sup>b)</sup> in ISM and amateur radio bands between 0.15 MHz and 80 MHz	Not applicable
		80 % AM at 1 kHz	80 % AM at 1 kHz	

Notes:

<sup>a)</sup> The following apply:

- All PATIENT-COUPLED cables shall be tested, either individually or bundled
- PATIENT-COUPLED cables shall be tested using a current clamp unless a current clamp is not suitable. In cases where a current clamp is not suitable, an EM clamp shall be used.
- No intentional decoupling device shall be used between the injection point and the PATIENT COUPLING POINT in any case.
- Testing may be performed at other modulation frequencies identified by the RISK MANAGEMENT PROCESS.
- Tubes that are intentionally filled with conductive liquids and intended to be connected to a PATIENT shall be considered to be PATIENT-COUPLED cables.
- If the frequency stepping skips over an ISM or amateur radio band, as applicable, an additional test frequency shall be used in the ISM or amateur radio band. This applies to each ISM and amateur radio band within the specified frequency range.
- The ISM (industrial, scientific and medical) bands between 0,15 MHz and 80 MHz are 6,765 MHz to 6,795 MHz; 13,553 MHz to 13,567 MHz; 26,957 MHz to 27,283 MHz; and 40,66 MHz to 40,70 MHz. The amateur radio bands between 0,15 MHz and 80 MHz are 1,8 MHz to 2,0 MHz, 3,5 MHz to 4,0 MHz, 5,3 MHz to 5,4 MHz, 7 MHz to 7,3 MHz, 10,1 MHz to 10,15 MHz, 14 MHz to 14,2 MHz, 18,07 MHz to 18,17 MHz, 21,0 MHz to 21,4 MHz, 24,89 MHz to 24,99 MHz, 28,0 MHz to 29,7 MHz and 50,0 MHz to 54,0 MHz.

<sup>b)</sup> r.m.s., before modulation is applied<sup>d)</sup> Discharges shall be applied with no connection to an artificial hand and no connection to PATIENT simulation. PATIENT simulation may be connected after the test as needed in order to verify BASIC SAFETY and ESSENTIAL PERFORMANCE.



## 2.1 Test results, continued

**Table 2.1-6: Signal input/output parts port results**

Phenomenon	Basic EMC standard or test method	Immunity test levels		Verdict
		Professional healthcare facility environment	HOME HEALTHCARE ENVIRONMENT	
ELECTROSTATIC DISCHARGE <sup>e)</sup>	IEC 61000-4-2	± 8 kV contact ± 2 kV, ±4 kV, ±8 kV, ±15 kV air		Pass
Electrical fast transients/bursts <sup>b), f)</sup>	IEC 61000-4-4	± 1 kV 100 kHz repetition frequency		Pass
Surges Line-to-ground <sup>d)</sup>	IEC 61000-4-5	± 2 kV		Pass
Conducted disturbances induced by RF fields <sup>b), d), g)</sup>	IEC 61000-4-6	3 V <sup>h)</sup> 0,15 – 80 MHz 6 V <sup>b)</sup> in ISM bands between 0.15 MHz and 80 MHz <sup>i)</sup> 80 % AM at 1 kHz <sup>c)</sup>	3 V <sup>h)</sup> 0,15 – 80 MHz 6 V <sup>h)</sup> in ISM and amateur radio bands between 0.15 MHz and 80 MHz <sup>i)</sup> 80 % AM at 1 kHz <sup>c)</sup>	Pass

Notes: <sup>1)</sup> EUT does not have Signal input/output parts PORT

<sup>a)</sup> This test applies only to output lines intended to connect directly to outdoor cables.

<sup>b)</sup> SIP/SOPS whose maximum cable length is less than 3 m in length are excluded.

<sup>c)</sup> Testing may be performed at other modulation frequencies identified by the RISK MANAGEMENT PROCESS.

<sup>d)</sup> Calibration for current injection clamps shall be performed in a 150 Ω system.

<sup>e)</sup> Connectors shall be tested per 8.3.2 and Table 4 of IEC 61000-4-2:2008. For insulated connector shells, perform air discharge testing to the connector shell and the pins using the rounded tip finger of the ESD generator, with the exception that the only connector pins that are tested are those that can be contacted or touched, under conditions of INTENDED USE, by the standard test finger shown in Figure 6 of the general standard, applied in a bent or straight position.

<sup>f)</sup> Capacitive coupling shall be used.

<sup>g)</sup> If the frequency stepping skips over an ISM or amateur radio band, as applicable, an additional test frequency shall be used in the ISM or amateur radio band. This applies to each ISM and amateur radio band within the specified frequency range.

<sup>h)</sup> r.m.s., before modulation is applied.

<sup>i)</sup> The ISM (industrial, scientific and medical) bands between 150 kHz and 80 MHz are 6,765 MHz to 6,795 MHz; 13,553 MHz to 13,567 MHz; 26,957 MHz to 27,283 MHz; and 40,66 MHz to 40,70 MHz. The amateur radio bands between 0,15 MHz and 80 MHz are 1,8 MHz to 2,0 MHz, 3,5 MHz to 4,0 MHz, 5,3 MHz to 5,4 MHz, 7 MHz to 7,3 MHz, 10,1 MHz to 10,15 MHz, 14 MHz to 14,2 MHz, 18,07 MHz to 18,17 MHz, 21,0 MHz to 21,4 MHz, 24,89 MHz to 24,99 MHz, 28,0 MHz to 29,7 MHz and 50,0 MHz to 54,0 MHz.

## Section 3 Equipment under test (EUT) details

---

### 3.1 Applicant

---

Company name	MRI Audio
Address	2720 Loker Avenue West, Suite N
City	Carlsbad
Province/State	California
Postal/Zip code	92008
Country	United States of America

### 3.2 Manufacturer

---

Company name	MRI Audio
Address	2720 Loker Avenue West, Suite N
City	Carlsbad
Province/State	California
Postal/Zip code	92008
Country	United States of America

### 3.3 Sample information

---

Receipt date	November 13, 2017
Nemko sample ID number	340891

### 3.4 EUT information

---

Product name	MRI Audio System
Model	PREM-100X
Serial number	NA
Part number	NA
Power requirements	100-240 50/60 Hz
Description/theory of operation	The MRIaudioPREM system is an MRI conditional audio solution that provides MRI patients with music, direct communication, and hearing protection.
Operational frequencies	50-60Hz
Software details	N/A
Intended use	The MRIaudioPREM-1000 & 1001 system is will produce high quality audio for patients undergoing MRI scans.
Intended environments	Professional healthcare

### 3.5 EUT exercise and monitoring details

---

The MRIaudioPREM system is an MRI conditional audio solution that provides MRI patients with music, direct communication, and hearing protection. The EUT was exercised by playing audio during the tests.

### 3.6 EUT setup details

**Table 3.6-1: EUT sub assemblies**

Description	Brand name	Model/Part number	Serial number	Rev.
Premium MRaudio music system	MRaudio Prem 1000	1000	N/A	A
Premium MRaudio music system	MRaudio Prem 1001	1001	N/A	A

**Table 3.6-2: EUT interface ports**

Description	Qty.
BNC port on Transducer	1
Two-prong (+/-) amplifier out (to Transducer)	1

**Table 3.6-3: Support equipment**

Description	Brand name	Model/Part number	Serial number	Rev.
Amplifier	MRaudio Amplifier	600	N/A	A

**Table 3.6-4: Inter-connection cables**

Cable description	From	To	Length (m)
100' Coaxial DB9 to raw end	Amplifier	Pen. Panel	30.48m
45' RF-Shielded BNC to DB9	Pen. Panel	Transducer	13.716m




Figure 3.6-1: Setup diagram

## Section 4 Engineering considerations

---

---

### 4.1 Modifications incorporated in the EUT

---

---

There were no modifications performed to the EUT during this assessment.

### 4.2 Technical judgment

---

None

### 4.3 Deviations from laboratory tests procedures

---

---

No deviations were made from laboratory procedures.

## Section 5 Test conditions

---

### 5.1 Atmospheric conditions

---

Temperature	15–30 °C
Relative humidity	20–75 %
Air pressure	86–106 kPa

When it is impracticable to carry out tests under these conditions, a note to this effect stating the ambient temperature and relative humidity during the tests shall be recorded and stated.

### 5.2 Power supply range

---

The normal test voltage for equipment to be connected to the mains shall be the nominal mains voltage. For the purpose of the present document, the nominal voltage shall be the declared voltage, or any of the declared voltages  $\pm 5\%$ , for which the equipment was designed.

## Section 6 Measurement uncertainty

---

### 6.1 Uncertainty of measurement

---

Nemko USA Inc. has calculated measurement uncertainty and is documented in EMC/MUC/001 "Uncertainty in EMC measurements." Measurement uncertainty was calculated using the methods described in CISPR 16-4 Specification for radio disturbance and immunity measuring apparatus and methods – Part 4: Uncertainty in EMC measurements; as well as described in UKAS LAB34: The expression of Uncertainty in EMC Testing. Measurement uncertainty calculations assume a coverage factor of  $K=2$  with 95% certainty.

## Section 7 Terms and definitions

---

### 7.1 Performance criterion

---

Immunity Pass fail criterion as provided by client.

Basic safety: No description provided.

Essential performance: No description provided.



## Section 8 Testing data

---

### 8.1 Radiated RF emissions

---

#### 8.1.1 References

---

CISPR 11: 2009 + A1: 2010

#### 8.1.2 Test summary

---

Verdict	Pass		
Test date	November 13, 2017	Temperature	20 °C
Test engineer	Rodel Resolme, EMC Test Engineer	Air pressure	1003 mbar
Test location	10m semi anechoic chamber	Relative humidity	48 %

#### 8.1.3 Notes

---

None.

#### 8.1.4 Setup details

---

EUT setup configuration	Table top
Test facility	10 m Semi anechoic chamber
Measuring distance	10 m
EUT mains voltage	120 V <sub>AC</sub> 60 Hz
Antenna height variation	1–4 m
Turn table position	0–360°
Measurement details	A preview measurement was generated with receiver in continuous scan or sweep mode while the EUT was rotated and antenna adjusted to maximize radiated emission. Emissions detected within 6 dB or above limit were re-measured with the appropriate detector against the correlating limit and recorded as the final measurement.

Receiver/spectrum analyzer settings for frequencies below 1 GHz:

Resolution bandwidth	120 kHz
Video bandwidth	300 kHz
Detector mode	Peak (preview measurement); Quasi-peak (final measurement)
Trace mode	Max Hold
Measurement time	100 ms (preview measurement); 1000 ms (final measurement)

8.1.4 Setup details, continued

---

**Table 8.1-1: Radiated RF emissions – equipment list**

Equipment	Manufacturer	Model no.	Asset no.	Cal cycle	Next cal.
EMC Test Receiver	Rohde & Schwarz	ESU 40	E1121	4/28/2016	4/28/2018
Antenna, Bilog	Schaffner-Chase	CBL 6111D	1763	11/28/2016	11/28/2017
Antenna, Horn	EMCO	3115	1033	7/27/2016	7/27/2018

Notes: None


**Table 8.1-2: Radiated RF emissions test software details**

Manufacturer of Software	Details
Rhode & Schwarz	EMC32 V10.0.0

Notes: None

8.1.5 Test data

Full Spectrum



The spectral plot is a summation of a vertical and horizontal scan. The spectral scan has been corrected with the associated transducer factors (i.e. antenna factors, cable loss, amplifier gains, and attenuators).

Figure 8.1-1: Radiated RF emissions spectral plot (30 to 1000 MHz)


Table 8.1-3: Radiated RF emissions (Quasi-Peak) results

Frequency (MHz)	QuasiPeak (dBµV/m)	Limit (dBµV/m)	Margin (dB)	Meas. Time (ms)	Bandwidth (kHz)	Height (cm)	Pol	Azimuth (deg)	Corr. (dB)
32.316000	12.76	40.00	27.24	5000.0	120.000	100.0	V	183.0	18.7
97.015000	7.31	40.00	32.69	5000.0	120.000	343.0	V	0.0	11.4
134.782000	9.68	40.00	30.32	5000.0	120.000	231.6	V	0.0	13.6
141.870000	9.38	40.00	30.62	5000.0	120.000	304.0	V	0.0	13.5
594.609000	21.38	47.00	25.62	5000.0	120.000	350.6	H	102.0	24.8
652.052500	22.67	47.00	24.33	5000.0	120.000	248.2	H	0.0	26.2
967.413000	28.89	47.00	18.11	5000.0	120.000	247.3	H	0.0	31.7

8.1.6 Setup photos



**Figure 8.1-2: Radiated RF emissions setup photo**



**Figure 8.1-3: Radiated RF emissions setup photo**

## 8.2 Conducted RF emissions

### 8.2.1 References

CISPR 11: 2009 + A1: 2010

### 8.2.2 Test summary

Verdict	Pass		
Test date	November 13, 2017	Temperature	20 °C
Test engineer	Rodel Resolme, EMC Test Engineer	Air pressure	1003 mbar
Test location	Ground Plane	Relative humidity	48 %

### 8.2.3 Notes

None

### 8.2.4 Setup details

Port under test	AC Mains
EUT setup configuration	Table top
EUT mains voltage	230 V <sub>AC</sub> ; 50 Hz
Measurement details	A preview measurement was generated with the receiver in continuous scan mode. Emissions detected within 6 dB or above limit were re-measured with the appropriate detector against the correlating limit and recorded as the final measurement.

Receiver settings:

Resolution bandwidth	9 kHz
Video bandwidth	30 kHz
Detector mode	Peak and Average (preview measurement); Quasi-peak and Average (final measurement)
Trace mode	Max Hold
Measurement time	100 ms (preview measurement); 1000 ms (final measurement)

**Table 8.2-1: Conducted RF emissions equipment list**

Equipment	Manufacturer	Model no.	Asset no.	Cal cycle	Next cal.
LISN	Rohde & Schwarz	ENV216	E1019	6/27/2017	6/27/2018
EMI Receiver	Rohde & Schwarz	ESCI 7	E1026	5/23/2017	5/23/2018

Notes: N/A - not applicable


**Table 8.2-2: Conducted RF emissions test software details**

Manufacturer of Software	Details
Rohde & Schwarz	EMC 32 V10.0

Notes: None

8.2.5 Test data

Full Spectrum



The spectral plot has been corrected with transducer factors. (i.e. cable loss, LISN factors, and attenuators)

**Figure 8.2-1: Conducted RF emissions spectral plot on phase & neutral line**


8.2.5 Test data, continued

Table 8.2-3: Conducted RF emissions (Quasi-Peak) results

Frequency (MHz)	QuasiPeak (dBµV)	Average (dBµV)	Limit (dBµV)	Margin (dB)	Meas. Time (ms)	Bandwidth (kHz)	Line	Filter	Corr. (dB)
0.164500	29.71	---	79.00	49.29	5000.0	9.000	N	ON	10.1
0.164500	---	16.14	66.00	49.86	5000.0	9.000	N	ON	10.1
0.304500	---	17.05	66.00	48.95	5000.0	9.000	N	ON	10.1
0.304500	26.05	---	79.00	52.95	5000.0	9.000	N	ON	10.1
0.580500	---	31.16	60.00	28.84	5000.0	9.000	L1	ON	10.1
0.580500	39.54	---	73.00	33.46	5000.0	9.000	L1	ON	10.1
0.644500	32.26	---	73.00	40.74	5000.0	9.000	L1	ON	10.1
0.644500	---	23.86	60.00	36.14	5000.0	9.000	L1	ON	10.1
0.676500	---	23.34	60.00	36.66	5000.0	9.000	L1	ON	10.1
0.676500	31.44	---	73.00	41.56	5000.0	9.000	L1	ON	10.1
1.456500	---	19.22	60.00	40.78	5000.0	9.000	L1	ON	10.1
1.456500	27.31	---	73.00	45.69	5000.0	9.000	L1	ON	10.1



8.2.6 Setup photos



**Figure 8.2-2: Conducted RF emissions setup photo**

## 8.3 Harmonic distortion

---

### 8.3.1 References

---

IEC 61000-3-2: 2014

Special Note: A more relevant publication of EN 61000-3-2 has been applied for this assessment.

### 8.3.2 Test summary

---

Verdict	Pass		
Test date	November 13, 2017	Temperature	20 °C
Test engineer	Rodel Resolme, EMC Test Engineer	Air pressure	1003 mbar
Test location	Ground Plane	Relative humidity	48 %

### 8.3.3 Notes

---

None

### 8.3.4 Setup details

---

Port under test	AC Mains
Measurement time	20 min
EUT mains voltage	230 V <sub>AC</sub> ; 50 Hz

**Table 8.3-1: Harmonic distortion equipment list**

Equipment	Manufacturer	Model no.	Asset no.	Cal cycle	Next cal.
AC/DC Power Source Analyzer	California Instruments	3001 ix	1851	1 yr.	7/9/2018

Notes: None

**Table 8.3-2: Harmonic distortion test software details**

Manufacturer of Software	Details
California Instruments	AC Source CIGui SII Version 3.0.0

Notes: None

8.3.5 Test data, continued


Measurement data

### Harmonics – Class-A per Ed. 4.0 (2014)(Run time)

EUT: MRI Audio System	Tested by: R. Resolme	
Test category: Class-A per Ed. 4.0 (2014) (European limits)	Test Margin: 100	
Test date: 11/13/2017	Start time: 2:03:54 PM	End time: 2:24:14 PM
Test duration (min): 20	Data file name: H-000933.cts_data	
Comment: Nex: 340891		
Customer: MRI Audio		


Test Result: Pass      Source qualification: Normal

#### Current & voltage waveforms



Harmonics and Class A limit line

European Limits



Test result: Pass Worst harmonic was #19 with 24.4% of the limit.

### Current Test Result Summary (Run time)

EUT: MRI Audio System  
 Test category: Class-A per Ed. 4.0 (2014) (European limits)  
 Test date: 11/13/2017  
 Test duration (min): 20  
 Comment: Nex: 340891  
 Customer: MRI Audio

Tested by: R. Resolme  
 Test Margin: 100  
 End time: 2:24:14 PM  
 Data file name: H-000933.cts\_data

Test Result: Pass Source qualification: Normal  
 THC(A): 0.135 I-THD(%): 195.0 POHC(A): 0.046 POHC Limit(A): 0.251  
 Highest parameter values during test:

V_RMS (Volts):	230.26	Frequency(Hz):	50.00
I_Peak (Amps):	2.077	I_RMS (Amps):	0.313
I_Fund (Amps):	0.086	Crest Factor:	12.276
Power (Watts):	16.1	Power Factor:	0.360

Harm#	Harms(avg)	100%Limit	%of Limit	Harms(max)	150%Limit	%of Limit	Status
2	0.013	1.080	1.2	0.015	1.620	1.0	Pass
3	0.048	2.300	2.1	0.069	3.450	2.0	Pass
4	0.013	0.430	3.0	0.015	0.645	2.3	Pass
5	0.047	1.140	4.1	0.067	1.710	3.9	Pass
6	0.012	0.300	4.2	0.015	0.450	3.3	Pass
7	0.045	0.770	5.9	0.065	1.155	5.6	Pass
8	0.012	0.230	5.2	0.014	0.345	4.0	Pass
9	0.043	0.400	10.8	0.061	0.600	10.2	Pass
10	0.011	0.184	6.1	0.013	0.276	4.7	Pass
11	0.041	0.330	12.5	0.058	0.495	11.7	Pass
12	0.010	0.153	6.8	0.012	0.230	5.2	Pass
13	0.038	0.210	18.3	0.053	0.315	17.0	Pass
14	0.010	0.131	7.3	0.011	0.197	5.5	Pass

15	0.035	0.150	23.6	0.049	0.225	21.7	Pass
16	0.009	0.115	7.5	0.010	0.173	5.6	Pass
17	0.032	0.132	24.4	0.044	0.198	22.1	Pass
18	0.008	0.102	7.6	0.009	0.153	5.7	Pass
19	0.029	0.118	24.4	0.039	0.178	21.8	Pass
20	0.007	0.092	7.4	0.008	0.138	5.6	Pass
21	0.026	0.107	23.9	0.034	0.161	20.9	Pass
22	0.006	0.084	7.0	0.007	0.125	5.4	Pass
23	0.022	0.098	22.8	0.028	0.147	19.4	Pass
24	0.005	0.077	6.5	0.006	0.115	5.2	Pass
25	0.019	0.090	21.1	0.024	0.135	17.4	Pass
26	0.004	0.071	N/A	0.005	0.107	N/A	Pass
27	0.016	0.083	19.0	0.019	0.125	15.1	Pass
28	0.004	0.066	N/A	0.005	0.099	N/A	Pass
29	0.013	0.078	16.7	0.015	0.116	12.9	Pass
30	0.003	0.061	N/A	0.004	0.092	N/A	Pass
31	0.010	0.073	14.2	0.012	0.109	10.9	Pass
32	0.003	0.058	N/A	0.004	0.086	N/A	Pass
33	0.008	0.068	11.6	0.009	0.102	9.3	Pass
34	0.002	0.054	N/A	0.003	0.081	N/A	Pass
35	0.006	0.064	9.0	0.008	0.096	7.8	Pass
36	0.002	0.051	N/A	0.003	0.077	N/A	Pass
37	0.004	0.061	N/A	0.006	0.091	N/A	Pass
38	0.002	0.048	N/A	0.003	0.073	N/A	Pass
39	0.003	0.058	N/A	0.005	0.087	N/A	Pass
40	0.002	0.046	N/A	0.003	0.069	N/A	Pass

### Voltage Source Verification Data (Run time)

EUT: MRI Audio System  
 Test category: Class-A per Ed. 4.0 (2014) (European limits)  
 Test date: 11/13/2017  
 Test duration (min): 20  
 Comment: Nex: 340891  
 Customer: MRI Audio

Tested by: R. Resolme  
 Test Margin: 100  
 Start time: 2:03:54 PM  
 End time: 2:24:14 PM  
 Data file name: H-000933.cts\_data

Test Result: Pass      Source qualification: Normal

#### Highest parameter values during test:

Voltage (Vrms):	230.26	Frequency(Hz):	50.00
I_Peak (Amps):	2.077	I_RMS (Amps):	0.313
I_Fund (Amps):	0.086	Crest Factor:	12.276
Power (Watts):	16.1	Power Factor:	0.360

Harm#	Harmonics V-rms	Limit V-rms	% of Limit	Status
2	0.060	0.460	13.11	OK
3	0.517	2.072	24.97	OK
4	0.037	0.460	7.96	OK
5	0.016	0.921	1.78	OK
6	0.047	0.460	10.28	OK
7	0.043	0.691	6.30	OK
8	0.008	0.461	1.67	OK
9	0.101	0.460	22.04	OK

**Section 10**  
**Test name**  
**Specification**

*Testing data*  
*Harmonic distortion*  
*IEC 60601-1-2: 2014*



10	0.004	0.460	0.95	OK
11	0.075	0.230	32.61	OK
12	0.008	0.230	3.38	OK
13	0.028	0.230	12.27	OK
14	0.004	0.230	1.72	OK
15	0.020	0.230	8.50	OK
16	0.010	0.230	4.20	OK
17	0.018	0.230	7.67	OK
18	0.014	0.230	6.08	OK
19	0.016	0.230	7.16	OK
20	0.013	0.230	5.82	OK
21	0.013	0.230	5.61	OK
22	0.004	0.230	1.92	OK
23	0.013	0.230	5.77	OK
24	0.006	0.230	2.66	OK
25	0.011	0.230	4.84	OK
26	0.004	0.230	1.60	OK
27	0.007	0.230	3.01	OK
28	0.004	0.230	1.78	OK
29	0.008	0.230	3.68	OK
30	0.006	0.230	2.48	OK
31	0.007	0.230	3.15	OK
32	0.003	0.230	1.26	OK
33	0.007	0.230	3.21	OK
34	0.003	0.230	1.39	OK
35	0.006	0.230	2.73	OK
36	0.003	0.230	1.44	OK
37	0.005	0.230	2.28	OK
38	0.004	0.230	1.62	OK
39	0.005	0.230	2.24	OK
40	0.007	0.230	3.21	OK

---

8.3.6 Setup photos



Figure 8.3-1: Harmonic distortion setup photo

## 8.4 Voltage fluctuations/flicker emissions

---

### 8.4.1 References

---

IEC 61000-3-3: 2013

Special Note: A more relevant publication of EN 61000-3-3 has been applied for this assessment.

### 8.4.2 Test summary

---

Verdict	Pass		
Test date	November 15, 2017	Temperature	20 °C
Test engineer	Rodel Resolme, EMC Test Engineer	Air pressure	1003 mbar
Test location	Ground Plane	Relative humidity	48 %

### 8.4.3 Notes

---

None

### 8.4.4 Setup details

---

Port under test	AC Mains
Measurement time	20 min
EUT mains voltage	230 V <sub>AC</sub> ; 50 Hz

**Table 8.4-1: Voltage fluctuations/flicker emissions equipment list**

Equipment	Manufacturer	Model no.	Asset no.	Cal cycle	Next cal.
Signal Conditioning Unit	Teseq/California Instruments	CCN 1000-3-75	961	7/9/2017	7/9/2018

Notes: NCR - no calibration required

**Table 8.4-2: Voltage fluctuations/flicker emissions test software details**

Manufacturer of Software	Details
California Instruments	AC Source CIGui SII Version 3.0.0

Notes: None



8.4.5 Test data, continued

Measurement data

### Flicker Test Summary per EN/IEC61000-3-3 (Run time)


EUT: MRI Audio System	Tested by: R. Resolme	
Test category: All parameters (European limits)	Test Margin: 100	
Test date: 11/13/2017	Start time: 2:31:39 PM	End time: 2:52:19 PM
Test duration (min): 20	Data file name: F-000934.cts_data	
Comment: Nex: 340891		
Customer: MRI Audio		

Test Result: Pass


Status: Test Completed

Pst<sub>i</sub> and limit line

European Limits



Plt and limit line



**Section 10**  
**Test name**  
**Specification**

*Testing data*  
*Voltage fluctuations/flicker emissions*  
*IEC 60601-1-2: 2014*




Parameter values recorded during the test:

Vrms at the end of test (Volt):	230.24			
Highest dt (%):	0.00	Test limit (%):	N/A	N/A
T-max (mS):	0	Test limit (mS):	500.0	Pass
Highest dc (%):	0.00	Test limit (%):	3.30	Pass
Highest dmax (%):	0.06	Test limit (%):	7.00	Pass
Highest Pst (10 min. period):	0.218	Test limit:	1.000	Pass
Highest Plt (2 hr. period):	0.119	Test limit:	0.650	Pass

---

8.4.6 Setup photos



**Figure 8.4-1: Voltage fluctuations/flicker emissions setup photo**

## 8.5 Radiated RF EM field

### 8.5.1 References

IEC 61000-4-3: 2006 + A1: 2007 + A2: 2010

### 8.5.2 Test summary

Verdict	Pass		
Test date	November 14, 2017	Temperature	20 °C
Test engineer	Rodel Resolme, EMC Test Engineer	Air pressure	1003 mbar
Test location	RFI Chamber	Relative humidity	48 %

### 8.5.3 Notes

None

### 8.5.4 Setup details

**Table 8.5-1: Radiated RF EM field equipment list**

Equipment	Manufacturer	Model no.	Asset no.	Cal cycle	Next cal.
RF Amplifier	Amplifier Research	500W1000M5	740	NCR	NCR
Pulse/Function Generator	HP	8116A	407	1 year	11/17/2017
Signal Generator	Agilent	E8254A	836	1 year	5/17/2018
E-Field Probe	Narda	EF0391	1791	2 year	6/27/2018
Broadband Field Meter	Narda	NBM-520	1789	2 year	6/27/2018
E-Field Probe	Narda	EF5091	1790	2 year	6/27/2018
RF Amplifier	Amplifier Research	200T1G3M3	743	NCR	NCR
RF Amplifier	Amplifier Research	200T2G8	848	NCR	NCR
Antenna, Biconical, high power	TDK RF Solutions	HBA-2030	1818	NCR	NCR
Antenna	Electrometrics	RGA-30	350	1 year	11/29/2017
Microwave Horn Antenna	Amplifier Research	AT4002A	728	NCR	NCR
Antenna, Horn	A.H. Systems	SAS-200/571	993	NCR	NCR

Notes: None

**Table 8.5-2: Radiated RF EM field test software details**

Manufacturer of Software	Details
ETS Lindgren	Tile 6

Notes: None

8.5.5 Test data

**Table 8.5-3: Radiated RF EM field results**

<b>Step size increment</b>	1 %		
<b>Dwell time</b>	3 s		
<b>Antenna polarization</b>	Vertical and Horizontal		
<b>Modulation</b>	CW signal amplitude modulated (AM) with 80 % depth with a 1 kHz sine wave		
<b>EUT setup configuration</b>	Choose an item.		
<b>EUT position facing antenna</b>	Front side, back side, left side and right side		
<b>TX antenna distance from EUT</b>	3 m		
<b>EUT mains input voltage</b>	Xxx V <sub>AC</sub> or V <sub>DC</sub> ; 50/60 Hz		
Frequency range, MHz		Test level, V/m <sup>1</sup>	Comments
80	2700	3	No degradation

Notes: EUT operational frequencies within specified test band were also assessed.

8.5.6 Setup photo




Figure 8.5-1: Radiated RF EM field setup photo

## 8.6 Proximity fields from RF wireless communications equipment

---

### 8.6.1 References

---

IEC 61000-4-3: 2006 + A1: 2007 + A2: 2010

### 8.6.2 Test summary

---

Verdict	Pass		
Test date	November 14, 2017	Temperature	20 °C
Test engineer	Rodel Resolme, EMC Test Engineer	Air pressure	1003 mbar
Test location	RFI Chamber	Relative humidity	48 %

### 8.6.3 Notes

---

None

### 8.6.4 Setup details

---

**Table 8.6-1: Proximity fields from RF wireless communications equipment equipment list**

Equipment	Manufacturer	Model no.	Asset no.	Cal cycle	Next cal.
Antenna, Horn	A.H. Systems	SAS-200/571	993	NCR	NCR
RF Amplifier	Amplifier Research	500W1000M5	740	NCR	NCR
Pulse/Function Generator	HP	8116A	407	1 year	11/17/2017
Signal Generator	Agilent	E8254A	836	1 year	5/17/2018
Antenna	Electrometrics	RGA-30	350	1 year	11/29/2017
Microwave Horn Antenna	Amplifier Research	AT4002A	728	NCR	NCR

Notes:            None

**Table 8.6-2: Proximity fields from RF wireless communications test software details**

Manufacturer of Software	Details
ETS Lindgren	Tile 6

Notes:            None

## 8.6.5 Test data

Table 8.6-3: Proximity fields from RF wireless communications results

Antenna polarization	Vertical and Horizontal
TX antenna distance from EUT	1 m
EUT setup configuration	Table top
EUT position facing antenna	Front side, back side, left side and right side
EUT mains input voltage	230V <sub>AC</sub> or V <sub>DC</sub> ; 50 Hz

Frequency range, MHz	Dwell time, s	Test level, V/m <sup>1</sup>	Modulation frequency, Hz	Comments
385	60	27	18	No degradation
450	60	28	18	No degradation
710	60	9	217	No degradation
745	60	9	217	No degradation
780	60	9	217	No degradation
810	60	28	18	No degradation
870	60	28	18	No degradation
930	60	28	18	No degradation
1720	60	28	217	No degradation
1845	60	28	217	No degradation
1970	60	28	217	No degradation
2450	60	28	217	No degradation
5240	60	9	217	No degradation
5500	60	9	217	No degradation
5785	60	9	217	No degradation

Notes: None



8.6.6 Setup photo




Figure 8.6-1: Proximity fields from RF wireless communications setup photo

## 8.7 Conducted disturbances induced by RF fields

---

### 8.7.1 References

---

IEC 61000-4-6: 2013

### 8.7.2 Test summary

---

Verdict	Pass		
Test date	November 15, 2017	Temperature	20 °C
Test engineer	Rodel Resolme, EMC Test Engineer	Air pressure	1003 mbar
Test location	Ground Plane	Relative humidity	48 %

### 8.7.3 Notes

---

None

### 8.7.4 Setup details

---

**Table 8.7-1: Conducted disturbances induced by RF fields equipment list**

Equipment	Manufacturer	Model no.	Asset no.	Cal cycle	Next cal.
Generator, signal	Hewlett Packard	8656B	D1182	1 year	1/25/2018
CDN	FCC	FCC-801-M3-25A	846	1 year	2/15/2018
Amplifier	IFI	SCCX%))	Rental	1 year	2/10/2018

Notes: None

**Table 8.7-2: Conducted disturbances induced by RF fields test software details**

Manufacturer of Software	Details
ETS Lindgren	Tile 6

Notes: None

8.7.5 Test data

**Table 8.7-3: Conducted disturbances induced by RF fields results**

<b>Frequency range:</b>	0.15–80 MHz
<b>Step size increment:</b>	1 %
<b>Dwell time<sup>1</sup>:</b>	3 s
<b>Signal level:</b>	3 V <sub>RMS</sub>
<b>Modulation:</b>	CW signal amplitude modulated (AM) with 80 % depth with a 1 kHz sine wave
<b>EUT mains input voltage</b>	230V <sub>AC</sub> ; 50 Hz

Ports investigated	Coupling method	50 Ω termination point	Comments
AC Mains	CDN		No degradation
Coaxial Cable	Clamp		No degradation

Notes: None

8.7.6 Setup photo



**Figure 8.7-1: Conducted disturbances induced by RF fields setup photo**



**Figure 8.7-2: Conducted disturbances induced by RF clamp setup photo**

## 8.8 Electrostatic discharge

### 8.8.1 References

IEC 61000-4-2: 2008

### 8.8.2 Test summary

Verdict	Pass		
Test date	November 16, 2017	Temperature	20 °C
Test engineer	Rodel Resolme, EMC Test Engineer	Air pressure	1002 mbar
Test location	Ground Plane	Relative humidity	48 %

### 8.8.3 Notes

None

### 8.8.4 Setup details

**Table 8.8-1: Electrostatic discharge equipment list**

Equipment	Manufacturer	Model no.	Asset no.	Cal cycle	Next cal.
ESD Gun	TeseQ	NSG 435	818	1 Year	3/23/2018

Notes: None

### 8.8.5 Test data

**Table 8.8-2: Electrostatic discharge results**

<b>EUT setup configuration:</b>	Table top		
<b>ESD repetition rate:</b>	1 pulse per second		
<b>Discharges:</b>	10 contact discharges and 10 air discharges at each polarity		
<b>EUT mains input voltage</b>	230Vac; 50 Hz		
<b>Contact discharge</b>	<b>Test voltage (±kV)</b>	<b>Comments</b>	
Please refer to "Electrostatic discharge test location points" photos of this section	8	No degradation	
<b>Indirect discharge</b>	<b>Test voltage (±kV)</b>	<b>Comments</b>	
HCP (all sides)	8	No degradation	
VCP (all sides)	8	No degradation	
<b>Air discharge</b>	<b>Test voltage (±kV)</b>	<b>Comments</b>	
Please refer to "Electrostatic discharge test location points" photos of this section	2, 4, 8, 15	No degradation	

Notes: None

8.8.5 Test data, continued







Figure 8.8-1: Electrostatic discharge test location point's photo

8.8.5 Test data, continued



Contact Discharges   
Air Discharges = 




Figure 8.8-2: Electrostatic discharge test location point's photo






Figure 8.8-3: Electrostatic discharge test location point's photo

8.8.6 Setup photo



Figure 8.8-4: Electrostatic discharge setup photo

## 8.9 Surge

---

### 8.9.1 References

---

IEC 61000-4-5: 2005

### 8.9.2 Test summary

---

Verdict	Pass		
Test date	November 14, 2017	Temperature	20 °C
Test engineer	Rodel Resolme, EMC Test Engineer	Air pressure	1003 mbar
Test location	Ground Plane	Relative humidity	48 %

### 8.9.3 Notes

---

None

### 8.9.4 Setup details

---

*Table 8.9-1: Surge equipment list*

Equipment	Manufacturer	Model no.	Asset no.	Cal cycle	Next cal.
Multitest Generator	TESEQ	NSG 3060	E1124	2 year	5/28/2018
Coupling Network	TESEQ	CDN 3061-C16	E1125	2 year	5/28/2018

Notes: None

*Table 8.9-2: Surge test software details*

Manufacturer of Software	Details
TESEQ	WIN 3000 V1.3.2

Notes: None

8.9.5 Test data

**Table 8.9-3: Surge at input a.c. power port results**

<b>Open circuit voltage (T<sub>1</sub> / T<sub>2</sub>):</b>	1.2/50 μs (T <sub>1</sub> = front time, T <sub>2</sub> = time to half value)
<b>Short circuit current (T<sub>1</sub> / T<sub>2</sub>):</b>	8/20 μs (T <sub>1</sub> = front time, T <sub>2</sub> = time to half value)
<b>Surge pulse interval:</b>	60 s
<b>Number of pulses:</b>	5 positive and 5 negative
<b>EUT mains input voltage:</b>	Xxx V <sub>AC</sub> or V <sub>DC</sub> ; 50/60 Hz

Test port	Coupling	Test voltage (±kV)	Comments
AC mains	Phase to Neutral	0.5, 1	No degradation
	Phase to ground	0.5, 1, 2	No degradation
	Neutral to ground	0.5, 1, 2	No degradation

- Notes:
- **Phase to neutral coupling** : Surge applied with generator output impedance set to 2 Ω
  - **Phase/neutral to ground coupling** : Surge applied with generator output impedance set to 12 Ω
  - Surge applied synchronous (relation to power supply): 0, 90, 180, and 270°

8.9.6 Setup photo




Figure 8.9-1: Surge setup photo

## 8.10 Electrical fast transients/bursts

---

### 8.10.1 References

---

IEC 61000-4-4: 2012

### 8.10.2 Test summary

---

Verdict	Pass		
Test date	November 14, 2017	Temperature	20 °C
Test engineer	Rodel Resolme, EMC Test Engineer	Air pressure	1002 mbar
Test location	Ground Plane	Relative humidity	49 %

### 8.10.3 Notes

---

None

### 8.10.4 Setup details

---

**Table 8.10-1: Electrical fast transients/bursts equipment list**

Equipment	Manufacturer	Model no.	Asset no.	Cal cycle	Next cal.
Multitest Generator	TESEQ	NSG 3060	E1124	2 year	5/28/2018
Coupling Network	TESEQ	CDN 3061-C16	E1125	2 year	5/28/2018

Notes: None

**Table 8.10-2: Electrical fast transients/bursts test software details**

Manufacturer of Software	Details
TESEQ	WIN 3000 V1.3.2

Notes: None

8.10.5 Test data

**Table 8.10-3: Electrical fast transients/bursts at power supply ports results**

<b>Wave shape (Tr / Td):</b>	5/50 ns (Tr = rise time, Td= duration time)
<b>Repetition frequency<sup>4</sup>:</b>	100 kHz
<b>Burst duration:</b>	0.75 ms
<b>Burst period:</b>	300 ms
<b>Test duration:</b>	60 s
<b>EUT mains input voltage:</b>	230V <sub>AC</sub> 50 Hz

Test port	Test voltage (±kV)	Comments
AC mains	2	No degradation

- Notes:
- Transient applied asynchronous (relation to power supply)
  - The test voltage was applied simultaneously between a ground reference plane and all of the power supply terminals and the protective or functional earth port on the EUT cabinet

**Table 8.10-4: Electrical fast transients/bursts at signal input/output parts PORT results**

<b>Wave shape (Tr / Td):</b>	5/50 ns (Tr = rise time, Td= duration time)
<b>Repetition frequency<sup>4</sup>:</b>	100 kHz
<b>Burst duration:</b>	0.75 ms
<b>Burst period:</b>	300 ms
<b>Test duration:</b>	60 s
<b>EUT mains input voltage:</b>	230V <sub>AC</sub> 50 Hz

Test port	Test voltage (±kV)	Comments
Coaxial Cable	1	No degradation

- Notes:
- The test voltage was applied via capacitive coupling clamp
  - SIP/SOPS whose maximum cable length is less than 3 m in length are excluded.

8.10.6 Setup photos



**Figure 8.10-1: Electrical fast transients/bursts setup photo**



## 8.11 Voltage dips and interruptions

---

### 8.11.1 References

---

IEC 61000-4-11: 2004

### 8.11.2 Test summary

---

Verdict	Pass		
Test date	November 13, 2017	Temperature	20 °C
Test engineer	Rodel Resolme, EMC Test Engineer	Air pressure	1003 mbar
Test location	Ground Plane	Relative humidity	48 %

### 8.11.3 Notes

---

None

### 8.11.4 Setup details

---

**Table 8.11-1: Voltage dips and interruptions equipment list**

Equipment	Manufacturer	Model no.	Asset no.	Cal cycle	Next cal.
Programmable AC & DC Power Source Analyzer	California Instruments	3001 ix	1851	1 yr.	7/9/2018

Notes: None

**Table 8.11-2: Voltage dips and interruptions test software details**

Manufacturer of Software	Details
California Instruments	AC Source CIGui SII Version 3.0.0

Notes: None

8.11.5 Test data

**Table 8.11-3: Voltage dips results**

<b>Variation/dip repetition:</b> Sequence of three dips/interruptions with an interval of 10 seconds between each test			
<b>Test port</b>	<b>Voltage reduction (%)</b>	<b>Periods</b>	<b>Comments</b>
AC mains (230 VAC, 50 Hz)	100	0.5	No degradation
AC mains (100 VAC, 60 Hz)	100	0.5	No degradation

Notes: Changes occurred at the 0°, 45°, 90°, 135°, 180°, 225°, 270° and 315° crossings of the voltage waveform

**Table 8.11-4: Voltage dips results**

<b>Variation/dip repetition:</b> Sequence of three dips/interruptions with an interval of 10 seconds between each test			
<b>Test port</b>	<b>Voltage reduction (%)</b>	<b>Periods</b>	<b>Comments</b>
AC mains (230 VAC, 50 Hz)	100	1	No degradation
	30	25	No degradation
AC mains (100 VAC, 60 Hz)	100	1	No degradation
	30	30	No degradation

Notes: Changes occurred at the 0 crossings of the voltage waveform

**Table 8.11-5: Voltage interruptions results**

<b>Variation/dip repetition:</b> Sequence of three dips/interruptions with an interval of 10 seconds between each test			
<b>Test port</b>	<b>Voltage reduction (%)</b>	<b>Periods</b>	<b>Comments</b>
AC mains (230 VAC, 50 Hz)	100	250	EUT power cycled
AC mains (100 VAC, 60 Hz)	100	300	EUT power cycled

Notes: Changes occurred at the 0 crossings of the voltage waveform

8.11.6 Setup photo

---



**Figure 8.11-1: Voltage dips and interruptions setup photo**

## 8.12 Power-frequency magnetic field

---

### 8.12.1 References

---

IEC 61000-4-8: 2009

Special Note: A more relevant publication of EN 61000-4-8 has been applied for this assessment.

### 8.12.2 Test summary

---

Verdict	Pass		
Test date	November 15, 2017	Temperature	20 °C
Test engineer	Rodel Resolme, EMC Test Engineer	Air pressure	1002 mbar
Test location	Ground Plane	Relative humidity	48 %

### 8.12.3 Notes

---

None

### 8.12.4 Setup details

---

**Table 8.12-1: Power-frequency magnetic field equipment list**

Equipment	Manufacturer	Model no.	Asset no.	Cal cycle	Next cal.
California Instruments	3001 ix	1851	1 yr.	1 yr.	7/9/2018
Small Magnetic Coil	Nemko	NA	821	NCR	NCR

Notes: None


8.12.5 Test data

**Table 8.12-2: Power-frequency magnetic field results**

<b>Assessment time:</b>	5 minutes at each loop polarization	
<b>Signal frequency:</b>	50 Hz	
<b>Magnetic field test level:</b>	30 A/m	
<b>EUT mains input voltage:</b>	230V <sub>AC</sub> ; 50 Hz	
<b>Loop polarization</b>	<b>Signal frequency (Hz)</b>	<b>Comments</b>
Vertical (aligned with AC power line)	50 or 60	No degradation
Vertical (perpendicular to AC power line)	50 or 60	No degradation
Horizontal	50 or 60	No degradation

Notes: Applies only to ME EQUIPMENT and ME SYSTEMS with magnetically sensitive components or circuitry.

8.12.6 Setup photo



**Figure 8.12-1: Power-frequency magnetic field setup photo**

## Section 9 EUT photos

### 9.1 External photos

---




Figure 9.1-1: Front view photo



Figure 9.1-2: Rear view photo





Figure 9.1-3: Side view photo